



SONA COLLEGE OF TECHNOLOGY

| An Autonomous Institution |

SALEM - 636 005 | INDIA

Approved by AICTE | Approved by UGC | Affiliated to Anna University | NAAC Accreditation: A++ Grade
All eligible programmes NBA Accredited | NIRF Ranked | ISO Certified

www.sonatech.ac.in

SCT/CIV/CON/MT/2026-27/04(4)

14.08.2026

To

Ms/ SALEM BRICKS
7/93/A, Anganvadi Street, Thalapllam,
Adaiyur Salem-636501.
GSTIN: 33GJEP1574C1ZG



Dear Sir,

Sub: Brick Test – Results – Reg.

Ref: Letter dated 07.08.2026

We are here with furnishing the results of the compression test conducted on the brick submitted by Client.

RED BRICK TEST REPORT


ID Mark: DOUBLE BOX LINE BRICK

Dimensions: 225mm x 105 mm x 75 mm

Date of Testing: 14.08.2026

Sl.No	Identification of Sample	Load (kN)	Compressive Strength (N/mm ²)	Average
1.	Sample 1	94	4.27	4.81 N/mm ²
2.	Sample 2	124	5.50	
3.	Sample 3	103	4.68	


Test Conducted by
(A. Prabu)


Co- Coordinator
(Dr. M. Logesh Kumar)


Coordinator
HoD / CIVIL

Note:

1. Any Correction in Certificate not attested shall invalidate this Certificate.
2. This report shall not be reproduced except in full without the written approval from the laboratory.
3. The values depicted are valid for the samples given by the client only. Sona College of Technology does not bear any responsibility of the validity in sampling.

*****End of Report*****