



SONA COLLEGE OF TECHNOLOGY

(Autonomous Institution)

SALEM - 636 005 | INDIA

Approved by AICTE | Affiliated to Anna University | NAAC-Accredited A-Grade
All eligible programmes NBA-Accredited | ISO-Certified

www.sonatech.ac.in

SCT/CIV/CON/MT/2026-27/09

31.08.2026

To

Ms/ SALEM BRICKS
7/93/A, Anganvadi Street, Thalapllam,
Adaiyur Salem-636501.
GSTIN: 33GJEPM1574C1ZG



Dear Sir,

Sub: Brick Test – Results – Reg.
Ref: Letter dated 07.08.2026

We are here with furnishing the results of the compression test conducted on the Wire cut brick submitted by Client.

RED BRICK TEST REPORT

ID Mark: Wire Cut Brick

Dimensions: 225 mm x 105 mm x 75 mm

Date of Testing: 25.08.2026

Sl.No	Identification of Sample	Load (kN)	Compressive Strength (N/mm ²)	Average
1.	Sample 1	473	20.02	17.95 N/mm ²
2.	Sample 2	491	20.78	
3.	Sample 3	309	13.07	

APB

Test Conducted by
(A. Prabu)

Dr. M. Logesh Kumar

Co- Coordinator
(Dr. M. Logesh Kumar)

Dr. M. Logesh Kumar

Coordinator
HoD / CIVIL

Note:

- Any Correction in Certificate not attested shall invalidate this Certificate.
- This report shall not be reproduced except in full without the written approval from the laboratory.
- The values depicted are valid for the samples given by the client only. Sona College of Technology does not bear any responsibility of the validity in sampling.

*****End of Report*****

